



PANEL LEGEND

ACC	=	REMOTE HEAT EXCHANGER CONTACT
AS	=	AIR FLOW SWITCH
BC	=	BLOWER CONTACTOR
BF	=	BLUVER FUSE
CB	=	CIRCUIT BREAKER
CC	=	COMPRESSOR CONTACTOR
CDH	=	CRANKCASE HEATER
CF	=	COMPRESSOR FUSE
DAPI	=	DATA ALARM PROCESSOR III
DP	=	DIFFERENTIAL PRESSURE SWITCH
DS	=	DISCONNECT SWITCH
ER	=	ENERGY SAVER RELAY
EMP	=	EXPANSION MODULE
FU	=	FUSE
HC	=	HUMIDIFIER CONTACTOR
HF	=	HUMIDIFIER FUSE
HCS	=	HDT GAS SOLENOID
HP	=	HIGH PRESSURE CUTOFF
HIC	=	REHEATER CONTACTOR
HIF	=	REHEATER FUSE
HUM	=	HUMIDIFIER
ITR	=	24V TO 24V ISOLATION TRANSFORMER
LLS	=	LIQUID LINE SOLENOID
LP	=	LOW PRESSURE CUTOFF
MOL	=	MOTOR OVERLOAD
MES	=	MANUAL OVERRIDE SWITCH
OLP	=	COMPRESSOR OVERLOAD RELAY
SFS	=	SECONDARY FLOAT SWITCH FOR THE CONDENSATE PUMP
SS	=	SURGE SUPPRESSOR
TB	=	TERMINAL BLOCK
TCO	=	THERMAL CUTOFF
TD	=	TIME DELAY
TR	=	TRANSFORMER
WS	=	WATER SENSING CHANGEOVER THERMOSTAT

- Ⓞ = TERMINAL BLOCK NO
- Ⓜ = PLINE PIN NO, INTERNAL TO DAPI
- Ⓜ = INDTEC TERMINAL STRIP CONNECTION
- = DAPI INTERNAL ELECTRONICS
- - - = OPTIONAL WIRING
- * = OPTIONAL COMPONENTS
- ** = APPLIES TO UNITS WITH LARGE COPELAND SCROLL COMPRESSORS (2180-2110)

DATA AIRE INC.
 230 WEST BLUERIDGE AVENUE
 ORANGE, CALIFORNIA 92665

DWG TITLE: **DATA TEMP CHILLED WATER DAP III PANEL**

JOB NO:	DRAWN BY: CABE
PROJECT NO: PCS013	CHECKED BY: MINH TRAN
OPTION:	EFFECTIVITY DATE: 07/1/09
	REVISION: B

DIAGRAM NO: **DTC-S-813**