



3/4" NPT COUPLING IS LOCATED IN COIL PAN NEAR THE CENTER OF UNIT TO MAINTAIN A POSITIVE DRAIN. A 3/4" NPT STREET ELBOW IS REQUIRED TO MAKE THIS FIELD CONNECTION.

ONE OF TWO 1" ACCESS HOLES PROVIDED FOR THE CONDENSATE DRAIN LINE (FIELD PIPING REQUIRED) ACCESS HOLES ARE LOCATED ON BOTH SIDES FIELD PIPING W/TRAP REQUIRED. DOTTED LINE INDICATES FIELD PIPING. USE HOLE ON OPPOSITE SIDE AS ALTERNATE ROUTE.

NOTES: UNIT LIQUID LINE CONNECTION SIZE IS 1/2" FOR BOTH SECTIONS.
 UNIT DISCHARGE LINE CONNECTION SIZE IS 1/2" FOR BOTH SECTIONS.
 THESE CONNECTION SIZES ARE NOT NECESSARILY THE RECOMMENDED FIELD PIPING SIZES.

NOTICE: THIS DRAWING EMBODIES A PROPRIETARY DESIGN, ORIGINATED BY DATA AIRE, INC. ALL DESIGN, MANUFACTURING, REPRODUCTION (EXCEPTING WHERE THE RECIPIENT HAS BEEN GIVEN THE EXPRESS RIGHT BY WRITTEN AGREEMENT TO PRODUCE THE DRAWING), USE AND SALE RIGHTS REGARDING THE SAME ARE EXPRESSLY RESERVED. IT IS SUBMITTED UNDER CONFIDENTIAL RELATIONSHIP FOR A SPECIFIC PURPOSE. THE RECIPIENT AGREES BY ACCEPTING THIS DRAWING NOT TO SUPPLY OR DISCLOSE ANY INFORMATION REGARDING IT TO ANY UNAUTHORIZED PERSON, OR TO INCORPORATE IN OTHER PROJECTS ANY SPECIAL FEATURES PECULIAR TO THIS DESIGN. ALL PATENT RIGHTS HERETO ARE EXPRESSLY RESERVED BY DATA AIRE, INC., ORANGE, CALIFORNIA, U.S.A.

ADD. VIEW A-A (SEE ECO)		9-23-02	E.D
RELEASED TO PRODUCTION		12-31-98	J.P
DESCRIPTION OF REVISION		DATE	BY
DRAWN BY: E. DIAZ	DATE: 9-23-02	230 W. BLUE RIDGE AVE. ORANGE, CALIFORNIA 92865	
ENGINEER #1		SCALE 1 = 1	WT. SHEET 1 OF 1
ENGINEER #2		TITLE	
		MINI CEILING SYSTEMS COMPONENT BREAKDOWN MINI DAMA-XXXX-C1 AIR COOLED SPLIT WITH INDOOR CONDENSER UNIT 1 TO 2 1/2 TON.	
NEXT ASSEMBLY	USED ON	DIR SL	FILE NO. 538900083A
APPLICATION		DRAWING NO.	538-900-083
FORM#: 4.5-003 REV. B		REV.	