

NOTES:

- △ DIMENSIONS NOTED ARE THE MINIMUM CLEARANCES REQUIRED BY THE FACTORY. CONSULT LOCAL BUILDING CODES AND NEC FOR ADDITIONAL CLEARANCE REQUIREMENTS.
- ALL STANDARD PIPING TERMINATES INSIDE OF CABINET. ALL OPTIONAL PIPING (TOP/SIDE) TERMINATES OUTSIDE OF CABINET.
- NOT ALL COMPONENTS AND OPTIONS ARE SHOWN. LOCATIONS MAY VARY DEPENDING ON OPTIONS.
- CONNECTION PIPE SIZE (2) INLET Ø3 1/8 (2) OUTLET Ø3 1/8.
- ALL DIMENSIONS ARE IN INCH [mm] FORMAT.

DAP ALARM PROCESSOR 4, (dap4)
UNIT MOUNTED DISPLAY

OPTIONAL DISCONNECT SWITCH

36" [914]

△ RECOMMENDED
CLEARANCE FOR
BOTH SIDES

40" [1016]

△ RECOMMENDED
CLEARANCE FOR
FRONT

PIPING AND
ELECTRICAL AREA
(SEE STANDARD
PIPING LOCATION)

EVAPORATOR
SUPPLY AIR

EVAPORATOR
SUPPLY AIR

EVAPORATOR
SUPPLY AIR

EVAPORATOR
SUPPLY AIR

FLOOR CUTOUT DIMENSIONS

DIMENSIONAL DATA

Ø0.75 CONDENSATE
DRAIN

(2) WATER IN
(2) WATER OUT

STANDARD PIPING LOCATION

FILTERS TO BE
ACCESSED FROM
FRONT OF THE UNIT

DATA ALARM
PROCESSOR 4, (dap4)
CONTROL MODULE

FILTERS

20"X25"X4" [508X635X102]
30 REQUIRED

CHILLED
WATER COIL

8X PLUG FAN

ELECTRICAL
BOX

PROPRIETARY AND CONFIDENTIAL

THE INFORMATION CONTAINED IN
THIS DRAWING IS THE SOLE PROPERTY
OF DATAIRE INC.
ANY REPRODUCTION IN PART OR AS
A WHOLE WITHOUT THE WRITTEN
PERMISSION OF DATAIRE INC. IS
PROHIBITED.

dataaire

230 W. Blue Ridge Ave
Orange, CA 92860

TITLE:

gForce GF
650 & 730 kW
CHILLED WATER DOWNFLOW

DRAWN		NAME	DATE	SCALE:	SIZE:	DWG. NO.	REV
DO		DO	4/24/2020	1:40	B	580-900-650	-
CHECKED		MATERIAL:		SHEET 1 OF 1			
BM		4/24/2020					