



CONNECTION POINT	A	B	C	D
ebrm GEN I	+20V	0-10V P.W.M.	GND	Not Req
Ziehl-Abegg	+24V	E1	GND	D1

- NOTES:**
1. ELECTRICAL INSTALLATION MUST COMPLY WITH ALL APPLICABLE CODES.
 2. MOTOR QUANTITY MAY VARY. IT DEPENDS ON UNIT MODEL.
 3. USE COPPER CONDUCTORS.

PANEL LEGEND

- D = DIODE
- DS = DISCONNECT SWITCH
- FB = FUSE BLOCK
- FU = FUSE
- R = RELAY
- SS = SURGE SUPPRESSOR
- TB = TERMINAL BLOCK
- TR = TRANSFORMER
- Ⓢ = TERMINAL BLOCK NO.
- = OPTIONAL WIRING
- * = OPTIONAL COMPONENTS
- ⚠ = DIODE NOT USED ON SINGLE MOTOR CONFIGURATION
- ⚠ = TB MAY BE OMITTED WHEN DISCONNECT SWITCH IS USED

© Copyright 2016 Data Aire, Inc.

dataaire
 230 W. BLUERIDGE AVE. ORANGE, CA. 92865

DWG TITLE:
**DATA AIRE
 AIR COOLED CONDENSER
 WITH EC FANS**

JOB NO:	DRAWN BY: M. COCHRAN
PROJECT NO: DRC5400	CHECKED BY: F. BELTRAN
OPTION:	EFFECTIVITY DATE: 06-04-2018
DIAGRAM NO: DRC-S-400	REVISION: L